

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/078/25	Model No.: KFKHQ-6	Date: 11-09-2025
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 078/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00771 To 780 And 775A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 775A and removed from the Lot/Batch							
771	Pass	772	Pass	773	Pass	774	Pass
775	Pass	776	Pass	777	Pass	778	Pass
779	Pass	780	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory