

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/307/25	Model No.: KFARQ-6-50%	Date: 22-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 307/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 30601 To 30700 And 30605A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 30605A and removed from the Lot/Batch							
30601	Pass	30602	Pass	30603	Pass	30604	Pass
30605	Pass	30606	Pass	30607	Pass	30608	Pass
30609	Pass	30610	Pass	30611	Pass	30612	Pass
30613	Pass	30614	Pass	30615	Pass	30616	Pass
30617	Pass	30618	Pass	30619	Pass	30620	Pass
30621	Pass	30622	Pass	30623	Pass	30624	Pass
30625	Pass	30626	Pass	30627	Pass	30628	Pass
30629	Pass	30630	Pass	30631	Pass	30632	Pass
30633	Pass	30634	Pass	30635	Pass	30636	Pass
30637	Pass	30638	Pass	30639	Pass	30640	Pass
30641	Pass	30642	Pass	30643	Pass	30644	Pass
30645	Pass	30646	Pass	30647	Pass	30648	Pass
30649	Pass	30650	Pass	30651	Pass	30652	Pass
30653	Pass	30654	Pass	30655	Pass	30656	Pass
30657	Pass	30658	Pass	30659	Pass	30660	Pass
30661	Pass	30662	Pass	30663	Pass	30664	Pass
30665	Pass	30666	Pass	30667	Pass	30668	Pass
30669	Pass	30670	Pass	30671	Pass	30672	Pass
30673	Pass	30674	Pass	30675	Pass	30676	Pass
30677	Pass	30678	Pass	30679	Pass	30680	Pass
30681	Pass	30682	Pass	30683	Pass	30684	Pass
30685	Pass	30686	Pass	30687	Pass	30688	Pass
30689	Pass	30690	Pass	30691	Pass	30692	Pass
30693	Pass	30694	Pass	30695	Pass	30696	Pass
30697	Pass	30698	Pass	30699	Pass	30700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory