

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/311/25	Model No.: KFARQ-6-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 311/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 31001 To 31100 And 31005A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 31005A and removed from the Lot/Batch							
31001	Pass	31002	Pass	31003	Pass	31004	Pass
31005	Pass	31006	Pass	31007	Pass	31008	Pass
31009	Pass	31010	Pass	31011	Pass	31012	Pass
31013	Pass	31014	Pass	31015	Pass	31016	Pass
31017	Pass	31018	Pass	31019	Pass	31020	Pass
31021	Pass	31022	Pass	31023	Pass	31024	Pass
31025	Pass	31026	Pass	31027	Pass	31028	Pass
31029	Pass	31030	Pass	31031	Pass	31032	Pass
31033	Pass	31034	Pass	31035	Pass	31036	Pass
31037	Pass	31038	Pass	31039	Pass	31040	Pass
31041	Pass	31042	Pass	31043	Pass	31044	Pass
31045	Pass	31046	Pass	31047	Pass	31048	Pass
31049	Pass	31050	Pass	31051	Pass	31052	Pass
31053	Pass	31054	Pass	31055	Pass	31056	Pass
31057	Pass	31058	Pass	31059	Pass	31060	Pass
31061	Pass	31062	Pass	31063	Pass	31064	Pass
31065	Pass	31066	Pass	31067	Pass	31068	Pass
31069	Pass	31070	Pass	31071	Pass	31072	Pass
31073	Pass	31074	Pass	31075	Pass	31076	Pass
31077	Pass	31078	Pass	31079	Pass	31080	Pass
31081	Pass	31082	Pass	31083	Pass	31084	Pass
31085	Pass	31086	Pass	31087	Pass	31088	Pass
31089	Pass	31090	Pass	31091	Pass	31092	Pass
31093	Pass	31094	Pass	31095	Pass	31096	Pass
31097	Pass	31098	Pass	31099	Pass	31100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory