

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/066/25	Model No.: KFARQ-4-50%	Date: 03-08-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 066/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06501 To 6600 And 6505A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6505A and removed from the Lot/Batch							
6501	Pass	6502	Pass	6503	Pass	6504	Pass
6505	Pass	6506	Pass	6507	Pass	6508	Pass
6509	Pass	6510	Pass	6511	Pass	6512	Pass
6513	Pass	6514	Pass	6515	Pass	6516	Pass
6517	Pass	6518	Pass	6519	Pass	6520	Pass
6521	Pass	6522	Pass	6523	Pass	6524	Pass
6525	Pass	6526	Pass	6527	Pass	6528	Pass
6529	Pass	6530	Pass	6531	Pass	6532	Pass
6533	Pass	6534	Pass	6535	Pass	6536	Pass
6537	Pass	6538	Pass	6539	Pass	6540	Pass
6541	Pass	6542	Pass	6543	Pass	6544	Pass
6545	Pass	6546	Pass	6547	Pass	6548	Pass
6549	Pass	6550	Pass	6551	Pass	6552	Pass
6553	Pass	6554	Pass	6555	Pass	6556	Pass
6557	Pass	6558	Pass	6559	Pass	6560	Pass
6561	Pass	6562	Pass	6563	Pass	6564	Pass
6565	Pass	6566	Pass	6567	Pass	6568	Pass
6569	Pass	6570	Pass	6571	Pass	6572	Pass
6573	Pass	6574	Pass	6575	Pass	6576	Pass
6577	Pass	6578	Pass	6579	Pass	6580	Pass
6581	Pass	6582	Pass	6583	Pass	6584	Pass
6585	Pass	6586	Pass	6587	Pass	6588	Pass
6589	Pass	6590	Pass	6591	Pass	6592	Pass
6593	Pass	6594	Pass	6595	Pass	6596	Pass
6597	Pass	6598	Pass	6599	Pass	6600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory