

HYDRO PRESSURE TEST

TC No.: HPT/KF/LI/HQ4/013/25	Model No.: KFLIHQ-4	Date: 12-07-2025
Type and Capacity of Extinguisher	: KFLIHQ-4-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 4 Ltr.	
Batch Number	: KFLIHQ4 013/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00121 To 130 And 125A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 125A and removed from the Lot/Batch							
121	Pass	122	Pass	123	Pass	124	Pass
125	Pass	126	Pass	127	Pass	128	Pass
129	Pass	130	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory