

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/306/25	Model No.: KFARQ-6-50%	Date: 22-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 306/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 30501 To 30600 And 30505A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 30505A and removed from the Lot/Batch							
30501	Pass	30502	Pass	30503	Pass	30504	Pass
30505	Pass	30506	Pass	30507	Pass	30508	Pass
30509	Pass	30510	Pass	30511	Pass	30512	Pass
30513	Pass	30514	Pass	30515	Pass	30516	Pass
30517	Pass	30518	Pass	30519	Pass	30520	Pass
30521	Pass	30522	Pass	30523	Pass	30524	Pass
30525	Pass	30526	Pass	30527	Pass	30528	Pass
30529	Pass	30530	Pass	30531	Pass	30532	Pass
30533	Pass	30534	Pass	30535	Pass	30536	Pass
30537	Pass	30538	Pass	30539	Pass	30540	Pass
30541	Pass	30542	Pass	30543	Pass	30544	Pass
30545	Pass	30546	Pass	30547	Pass	30548	Pass
30549	Pass	30550	Pass	30551	Pass	30552	Pass
30553	Pass	30554	Pass	30555	Pass	30556	Pass
30557	Pass	30558	Pass	30559	Pass	30560	Pass
30561	Pass	30562	Pass	30563	Pass	30564	Pass
30565	Pass	30566	Pass	30567	Pass	30568	Pass
30569	Pass	30570	Pass	30571	Pass	30572	Pass
30573	Pass	30574	Pass	30575	Pass	30576	Pass
30577	Pass	30578	Pass	30579	Pass	30580	Pass
30581	Pass	30582	Pass	30583	Pass	30584	Pass
30585	Pass	30586	Pass	30587	Pass	30588	Pass
30589	Pass	30590	Pass	30591	Pass	30592	Pass
30593	Pass	30594	Pass	30595	Pass	30596	Pass
30597	Pass	30598	Pass	30599	Pass	30600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory