

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/304/25	Model No.: KFARQ-6-50%	Date: 22-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 304/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 30301 To 30400 And 30305A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 30305A and removed from the Lot/Batch							
30301	Pass	30302	Pass	30303	Pass	30304	Pass
30305	Pass	30306	Pass	30307	Pass	30308	Pass
30309	Pass	30310	Pass	30311	Pass	30312	Pass
30313	Pass	30314	Pass	30315	Pass	30316	Pass
30317	Pass	30318	Pass	30319	Pass	30320	Pass
30321	Pass	30322	Pass	30323	Pass	30324	Pass
30325	Pass	30326	Pass	30327	Pass	30328	Pass
30329	Pass	30330	Pass	30331	Pass	30332	Pass
30333	Pass	30334	Pass	30335	Pass	30336	Pass
30337	Pass	30338	Pass	30339	Pass	30340	Pass
30341	Pass	30342	Pass	30343	Pass	30344	Pass
30345	Pass	30346	Pass	30347	Pass	30348	Pass
30349	Pass	30350	Pass	30351	Pass	30352	Pass
30353	Pass	30354	Pass	30355	Pass	30356	Pass
30357	Pass	30358	Pass	30359	Pass	30360	Pass
30361	Pass	30362	Pass	30363	Pass	30364	Pass
30365	Pass	30366	Pass	30367	Pass	30368	Pass
30369	Pass	30370	Pass	30371	Pass	30372	Pass
30373	Pass	30374	Pass	30375	Pass	30376	Pass
30377	Pass	30378	Pass	30379	Pass	30380	Pass
30381	Pass	30382	Pass	30383	Pass	30384	Pass
30385	Pass	30386	Pass	30387	Pass	30388	Pass
30389	Pass	30390	Pass	30391	Pass	30392	Pass
30393	Pass	30394	Pass	30395	Pass	30396	Pass
30397	Pass	30398	Pass	30399	Pass	30400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory