

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/HQ/006/25

Model No.: KMCHQ-10-FE36

Date: 24-02-2025

Type and Capacity of Extinguisher : KMCHQ-10-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 10 Kg.

Batch Number : KMCHQ10 006/25

Batch Quantity : 20.00 Nos.

Serial Numbers : 00101 To 120

Month of Manufacturing : Feb/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00101 To 120 and removed from the Lot/Batch							
101	Pass	102	Pass	103	Pass	104	Pass
105	Pass	106	Pass	107	Pass	108	Pass
109	Pass	110	Pass	111	Pass	112	Pass
113	Pass	114	Pass	115	Pass	116	Pass
117	Pass	118	Pass	119	Pass	120	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**