

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/A50/RQ/037/25	Model No.: KMPRQ-5-50%	Date: 27-07-2025
Type and Capacity of Extinguisher	: KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMPRQ50%5 037/25	
Batch Quantity	: 100.00 Nos.	
Serial Numbers	: 03601 To 3700	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03601 To 3700 and removed from the Lot/Batch							
3601	Pass	3602	Pass	3603	Pass	3604	Pass
3605	Pass	3606	Pass	3607	Pass	3608	Pass
3609	Pass	3610	Pass	3611	Pass	3612	Pass
3613	Pass	3614	Pass	3615	Pass	3616	Pass
3617	Pass	3618	Pass	3619	Pass	3620	Pass
3621	Pass	3622	Pass	3623	Pass	3624	Pass
3625	Pass	3626	Pass	3627	Pass	3628	Pass
3629	Pass	3630	Pass	3631	Pass	3632	Pass
3633	Pass	3634	Pass	3635	Pass	3636	Pass
3637	Pass	3638	Pass	3639	Pass	3640	Pass
3641	Pass	3642	Pass	3643	Pass	3644	Pass
3645	Pass	3646	Pass	3647	Pass	3648	Pass
3649	Pass	3650	Pass	3651	Pass	3652	Pass
3653	Pass	3654	Pass	3655	Pass	3656	Pass
3657	Pass	3658	Pass	3659	Pass	3660	Pass
3661	Pass	3662	Pass	3663	Pass	3664	Pass
3665	Pass	3666	Pass	3667	Pass	3668	Pass
3669	Pass	3670	Pass	3671	Pass	3672	Pass
3673	Pass	3674	Pass	3675	Pass	3676	Pass
3677	Pass	3678	Pass	3679	Pass	3680	Pass
3681	Pass	3682	Pass	3683	Pass	3684	Pass
3685	Pass	3686	Pass	3687	Pass	3688	Pass
3689	Pass	3690	Pass	3691	Pass	3692	Pass
3693	Pass	3694	Pass	3695	Pass	3696	Pass
3697	Pass	3698	Pass	3699	Pass	3700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory