

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/064/25	Model No.: KMCRQ-5	Date: 20-09-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 064/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03151 To 3200	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03151 To 3200 and removed from the Lot/Batch							
3151	Pass	3152	Pass	3153	Pass	3154	Pass
3155	Pass	3156	Pass	3157	Pass	3158	Pass
3159	Pass	3160	Pass	3161	Pass	3162	Pass
3163	Pass	3164	Pass	3165	Pass	3166	Pass
3167	Pass	3168	Pass	3169	Pass	3170	Pass
3171	Pass	3172	Pass	3173	Pass	3174	Pass
3175	Pass	3176	Pass	3177	Pass	3178	Pass
3179	Pass	3180	Pass	3181	Pass	3182	Pass
3183	Pass	3184	Pass	3185	Pass	3186	Pass
3187	Pass	3188	Pass	3189	Pass	3190	Pass
3191	Pass	3192	Pass	3193	Pass	3194	Pass
3195	Pass	3196	Pass	3197	Pass	3198	Pass
3199	Pass	3200	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory