

HYDRO PRESSURE TEST

TC No.: HPT/A4/MDS/RQ/010/25	Model No.: MDSRQ-4	Date: 27-08-2025
Type and Capacity of Extinguisher	: MDSRQ-4-Kanex BC Dry Powder SP Fire Extinguisher Cap. 4 Kg	
Batch Number	: MDSRQ4 010/25	
Batch Quantity	: 51.00 Nos.	
Serial Numbers	: 00451 To 500 And 455A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 455A and removed from the Lot/Batch							
451	Pass	452	Pass	453	Pass	454	Pass
455	Pass	456	Pass	457	Pass	458	Pass
459	Pass	460	Pass	461	Pass	462	Pass
463	Pass	464	Pass	465	Pass	466	Pass
467	Pass	468	Pass	469	Pass	470	Pass
471	Pass	472	Pass	473	Pass	474	Pass
475	Pass	476	Pass	477	Pass	478	Pass
479	Pass	480	Pass	481	Pass	482	Pass
483	Pass	484	Pass	485	Pass	486	Pass
487	Pass	488	Pass	489	Pass	490	Pass
491	Pass	492	Pass	493	Pass	494	Pass
495	Pass	496	Pass	497	Pass	498	Pass
499	Pass	500	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory