

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/260/25	Model No.: MARQ-6-50%	Date: 03-08-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 260/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25901 To 26000 And 25905A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25905A and removed from the Lot/Batch							
25901	Pass	25902	Pass	25903	Pass	25904	Pass
25905	Pass	25906	Pass	25907	Pass	25908	Pass
25909	Pass	25910	Pass	25911	Pass	25912	Pass
25913	Pass	25914	Pass	25915	Pass	25916	Pass
25917	Pass	25918	Pass	25919	Pass	25920	Pass
25921	Pass	25922	Pass	25923	Pass	25924	Pass
25925	Pass	25926	Pass	25927	Pass	25928	Pass
25929	Pass	25930	Pass	25931	Pass	25932	Pass
25933	Pass	25934	Pass	25935	Pass	25936	Pass
25937	Pass	25938	Pass	25939	Pass	25940	Pass
25941	Pass	25942	Pass	25943	Pass	25944	Pass
25945	Pass	25946	Pass	25947	Pass	25948	Pass
25949	Pass	25950	Pass	25951	Pass	25952	Pass
25953	Pass	25954	Pass	25955	Pass	25956	Pass
25957	Pass	25958	Pass	25959	Pass	25960	Pass
25961	Pass	25962	Pass	25963	Pass	25964	Pass
25965	Pass	25966	Pass	25967	Pass	25968	Pass
25969	Pass	25970	Pass	25971	Pass	25972	Pass
25973	Pass	25974	Pass	25975	Pass	25976	Pass
25977	Pass	25978	Pass	25979	Pass	25980	Pass
25981	Pass	25982	Pass	25983	Pass	25984	Pass
25985	Pass	25986	Pass	25987	Pass	25988	Pass
25989	Pass	25990	Pass	25991	Pass	25992	Pass
25993	Pass	25994	Pass	25995	Pass	25996	Pass
25997	Pass	25998	Pass	25999	Pass	26000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory