

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A50/RQ/054/25     | Model No.: MARQ-4-50%                                          | Date: 20-07-2025 |
| Type and Capacity of Extinguisher | : MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : MARQ50%4 054/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 05301 To 5400 And 5305A                                      |                  |
| Month of Manufacturing            | : Jul/25                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 5305A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 5301                                                         | Pass   | 5302     | Pass   | 5303     | Pass   | 5304     | Pass   |
| 5305                                                         | Pass   | 5306     | Pass   | 5307     | Pass   | 5308     | Pass   |
| 5309                                                         | Pass   | 5310     | Pass   | 5311     | Pass   | 5312     | Pass   |
| 5313                                                         | Pass   | 5314     | Pass   | 5315     | Pass   | 5316     | Pass   |
| 5317                                                         | Pass   | 5318     | Pass   | 5319     | Pass   | 5320     | Pass   |
| 5321                                                         | Pass   | 5322     | Pass   | 5323     | Pass   | 5324     | Pass   |
| 5325                                                         | Pass   | 5326     | Pass   | 5327     | Pass   | 5328     | Pass   |
| 5329                                                         | Pass   | 5330     | Pass   | 5331     | Pass   | 5332     | Pass   |
| 5333                                                         | Pass   | 5334     | Pass   | 5335     | Pass   | 5336     | Pass   |
| 5337                                                         | Pass   | 5338     | Pass   | 5339     | Pass   | 5340     | Pass   |
| 5341                                                         | Pass   | 5342     | Pass   | 5343     | Pass   | 5344     | Pass   |
| 5345                                                         | Pass   | 5346     | Pass   | 5347     | Pass   | 5348     | Pass   |
| 5349                                                         | Pass   | 5350     | Pass   | 5351     | Pass   | 5352     | Pass   |
| 5353                                                         | Pass   | 5354     | Pass   | 5355     | Pass   | 5356     | Pass   |
| 5357                                                         | Pass   | 5358     | Pass   | 5359     | Pass   | 5360     | Pass   |
| 5361                                                         | Pass   | 5362     | Pass   | 5363     | Pass   | 5364     | Pass   |
| 5365                                                         | Pass   | 5366     | Pass   | 5367     | Pass   | 5368     | Pass   |
| 5369                                                         | Pass   | 5370     | Pass   | 5371     | Pass   | 5372     | Pass   |
| 5373                                                         | Pass   | 5374     | Pass   | 5375     | Pass   | 5376     | Pass   |
| 5377                                                         | Pass   | 5378     | Pass   | 5379     | Pass   | 5380     | Pass   |
| 5381                                                         | Pass   | 5382     | Pass   | 5383     | Pass   | 5384     | Pass   |
| 5385                                                         | Pass   | 5386     | Pass   | 5387     | Pass   | 5388     | Pass   |
| 5389                                                         | Pass   | 5390     | Pass   | 5391     | Pass   | 5392     | Pass   |
| 5393                                                         | Pass   | 5394     | Pass   | 5395     | Pass   | 5396     | Pass   |
| 5397                                                         | Pass   | 5398     | Pass   | 5399     | Pass   | 5400     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**