

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/225/25	Model No.: MARQ-6-50%	Date: 18-07-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 225/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22401 To 22500 And 22405A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22405A and removed from the Lot/Batch							
22401	Pass	22402	Pass	22403	Pass	22404	Pass
22405	Pass	22406	Pass	22407	Pass	22408	Pass
22409	Pass	22410	Pass	22411	Pass	22412	Pass
22413	Pass	22414	Pass	22415	Pass	22416	Pass
22417	Pass	22418	Pass	22419	Pass	22420	Pass
22421	Pass	22422	Pass	22423	Pass	22424	Pass
22425	Pass	22426	Pass	22427	Pass	22428	Pass
22429	Pass	22430	Pass	22431	Pass	22432	Pass
22433	Pass	22434	Pass	22435	Pass	22436	Pass
22437	Pass	22438	Pass	22439	Pass	22440	Pass
22441	Pass	22442	Pass	22443	Pass	22444	Pass
22445	Pass	22446	Pass	22447	Pass	22448	Pass
22449	Pass	22450	Pass	22451	Pass	22452	Pass
22453	Pass	22454	Pass	22455	Pass	22456	Pass
22457	Pass	22458	Pass	22459	Pass	22460	Pass
22461	Pass	22462	Pass	22463	Pass	22464	Pass
22465	Pass	22466	Pass	22467	Pass	22468	Pass
22469	Pass	22470	Pass	22471	Pass	22472	Pass
22473	Pass	22474	Pass	22475	Pass	22476	Pass
22477	Pass	22478	Pass	22479	Pass	22480	Pass
22481	Pass	22482	Pass	22483	Pass	22484	Pass
22485	Pass	22486	Pass	22487	Pass	22488	Pass
22489	Pass	22490	Pass	22491	Pass	22492	Pass
22493	Pass	22494	Pass	22495	Pass	22496	Pass
22497	Pass	22498	Pass	22499	Pass	22500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory