

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/235/25	Model No.: MARQ-6-50%	Date: 22-07-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 235/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23401 To 23500 And 23405A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23405A and removed from the Lot/Batch							
23401	Pass	23402	Pass	23403	Pass	23404	Pass
23405	Pass	23406	Pass	23407	Pass	23408	Pass
23409	Pass	23410	Pass	23411	Pass	23412	Pass
23413	Pass	23414	Pass	23415	Pass	23416	Pass
23417	Pass	23418	Pass	23419	Pass	23420	Pass
23421	Pass	23422	Pass	23423	Pass	23424	Pass
23425	Pass	23426	Pass	23427	Pass	23428	Pass
23429	Pass	23430	Pass	23431	Pass	23432	Pass
23433	Pass	23434	Pass	23435	Pass	23436	Pass
23437	Pass	23438	Pass	23439	Pass	23440	Pass
23441	Pass	23442	Pass	23443	Pass	23444	Pass
23445	Pass	23446	Pass	23447	Pass	23448	Pass
23449	Pass	23450	Pass	23451	Pass	23452	Pass
23453	Pass	23454	Pass	23455	Pass	23456	Pass
23457	Pass	23458	Pass	23459	Pass	23460	Pass
23461	Pass	23462	Pass	23463	Pass	23464	Pass
23465	Pass	23466	Pass	23467	Pass	23468	Pass
23469	Pass	23470	Pass	23471	Pass	23472	Pass
23473	Pass	23474	Pass	23475	Pass	23476	Pass
23477	Pass	23478	Pass	23479	Pass	23480	Pass
23481	Pass	23482	Pass	23483	Pass	23484	Pass
23485	Pass	23486	Pass	23487	Pass	23488	Pass
23489	Pass	23490	Pass	23491	Pass	23492	Pass
23493	Pass	23494	Pass	23495	Pass	23496	Pass
23497	Pass	23498	Pass	23499	Pass	23500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory