

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/242/25	Model No.: MARQ-6-50%	Date: 26-07-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 242/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24101 To 24200 And 24105A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24105A and removed from the Lot/Batch							
24101	Pass	24102	Pass	24103	Pass	24104	Pass
24105	Pass	24106	Pass	24107	Pass	24108	Pass
24109	Pass	24110	Pass	24111	Pass	24112	Pass
24113	Pass	24114	Pass	24115	Pass	24116	Pass
24117	Pass	24118	Pass	24119	Pass	24120	Pass
24121	Pass	24122	Pass	24123	Pass	24124	Pass
24125	Pass	24126	Pass	24127	Pass	24128	Pass
24129	Pass	24130	Pass	24131	Pass	24132	Pass
24133	Pass	24134	Pass	24135	Pass	24136	Pass
24137	Pass	24138	Pass	24139	Pass	24140	Pass
24141	Pass	24142	Pass	24143	Pass	24144	Pass
24145	Pass	24146	Pass	24147	Pass	24148	Pass
24149	Pass	24150	Pass	24151	Pass	24152	Pass
24153	Pass	24154	Pass	24155	Pass	24156	Pass
24157	Pass	24158	Pass	24159	Pass	24160	Pass
24161	Pass	24162	Pass	24163	Pass	24164	Pass
24165	Pass	24166	Pass	24167	Pass	24168	Pass
24169	Pass	24170	Pass	24171	Pass	24172	Pass
24173	Pass	24174	Pass	24175	Pass	24176	Pass
24177	Pass	24178	Pass	24179	Pass	24180	Pass
24181	Pass	24182	Pass	24183	Pass	24184	Pass
24185	Pass	24186	Pass	24187	Pass	24188	Pass
24189	Pass	24190	Pass	24191	Pass	24192	Pass
24193	Pass	24194	Pass	24195	Pass	24196	Pass
24197	Pass	24198	Pass	24199	Pass	24200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory