

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/303/25	Model No.: KFARQ-6-50%	Date: 18-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 303/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 30201 To 30300 And 30205A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 30205A and removed from the Lot/Batch							
30201	Pass	30202	Pass	30203	Pass	30204	Pass
30205	Pass	30206	Pass	30207	Pass	30208	Pass
30209	Pass	30210	Pass	30211	Pass	30212	Pass
30213	Pass	30214	Pass	30215	Pass	30216	Pass
30217	Pass	30218	Pass	30219	Pass	30220	Pass
30221	Pass	30222	Pass	30223	Pass	30224	Pass
30225	Pass	30226	Pass	30227	Pass	30228	Pass
30229	Pass	30230	Pass	30231	Pass	30232	Pass
30233	Pass	30234	Pass	30235	Pass	30236	Pass
30237	Pass	30238	Pass	30239	Pass	30240	Pass
30241	Pass	30242	Pass	30243	Pass	30244	Pass
30245	Pass	30246	Pass	30247	Pass	30248	Pass
30249	Pass	30250	Pass	30251	Pass	30252	Pass
30253	Pass	30254	Pass	30255	Pass	30256	Pass
30257	Pass	30258	Pass	30259	Pass	30260	Pass
30261	Pass	30262	Pass	30263	Pass	30264	Pass
30265	Pass	30266	Pass	30267	Pass	30268	Pass
30269	Pass	30270	Pass	30271	Pass	30272	Pass
30273	Pass	30274	Pass	30275	Pass	30276	Pass
30277	Pass	30278	Pass	30279	Pass	30280	Pass
30281	Pass	30282	Pass	30283	Pass	30284	Pass
30285	Pass	30286	Pass	30287	Pass	30288	Pass
30289	Pass	30290	Pass	30291	Pass	30292	Pass
30293	Pass	30294	Pass	30295	Pass	30296	Pass
30297	Pass	30298	Pass	30299	Pass	30300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory