

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/A50/RQ/047/25	Model No.: KMPRQ-5-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMPRQ50%5 047/25	
Batch Quantity	: 100.00 Nos.	
Serial Numbers	: 04601 To 4700	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 04601 To 4700 and removed from the Lot/Batch							
4601	Pass	4602	Pass	4603	Pass	4604	Pass
4605	Pass	4606	Pass	4607	Pass	4608	Pass
4609	Pass	4610	Pass	4611	Pass	4612	Pass
4613	Pass	4614	Pass	4615	Pass	4616	Pass
4617	Pass	4618	Pass	4619	Pass	4620	Pass
4621	Pass	4622	Pass	4623	Pass	4624	Pass
4625	Pass	4626	Pass	4627	Pass	4628	Pass
4629	Pass	4630	Pass	4631	Pass	4632	Pass
4633	Pass	4634	Pass	4635	Pass	4636	Pass
4637	Pass	4638	Pass	4639	Pass	4640	Pass
4641	Pass	4642	Pass	4643	Pass	4644	Pass
4645	Pass	4646	Pass	4647	Pass	4648	Pass
4649	Pass	4650	Pass	4651	Pass	4652	Pass
4653	Pass	4654	Pass	4655	Pass	4656	Pass
4657	Pass	4658	Pass	4659	Pass	4660	Pass
4661	Pass	4662	Pass	4663	Pass	4664	Pass
4665	Pass	4666	Pass	4667	Pass	4668	Pass
4669	Pass	4670	Pass	4671	Pass	4672	Pass
4673	Pass	4674	Pass	4675	Pass	4676	Pass
4677	Pass	4678	Pass	4679	Pass	4680	Pass
4681	Pass	4682	Pass	4683	Pass	4684	Pass
4685	Pass	4686	Pass	4687	Pass	4688	Pass
4689	Pass	4690	Pass	4691	Pass	4692	Pass
4693	Pass	4694	Pass	4695	Pass	4696	Pass
4697	Pass	4698	Pass	4699	Pass	4700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory