

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/HQ/015/25	Model No.: KMCHQ-10-FE36	Date: 11-09-2025
Type and Capacity of Extinguisher	: KMCHQ-10-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCHQ10 015/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00281 To 300	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00281 To 300 and removed from the Lot/Batch							
281	Pass	282	Pass	283	Pass	284	Pass
285	Pass	286	Pass	287	Pass	288	Pass
289	Pass	290	Pass	291	Pass	292	Pass
293	Pass	294	Pass	295	Pass	296	Pass
297	Pass	298	Pass	299	Pass	300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory