

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/147/25	Model No.: MARQ-6-40%	Date: 19-08-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 147/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14601 To 14700 And 14605A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14605A and removed from the Lot/Batch							
14601	Pass	14602	Pass	14603	Pass	14604	Pass
14605	Pass	14606	Pass	14607	Pass	14608	Pass
14609	Pass	14610	Pass	14611	Pass	14612	Pass
14613	Pass	14614	Pass	14615	Pass	14616	Pass
14617	Pass	14618	Pass	14619	Pass	14620	Pass
14621	Pass	14622	Pass	14623	Pass	14624	Pass
14625	Pass	14626	Pass	14627	Pass	14628	Pass
14629	Pass	14630	Pass	14631	Pass	14632	Pass
14633	Pass	14634	Pass	14635	Pass	14636	Pass
14637	Pass	14638	Pass	14639	Pass	14640	Pass
14641	Pass	14642	Pass	14643	Pass	14644	Pass
14645	Pass	14646	Pass	14647	Pass	14648	Pass
14649	Pass	14650	Pass	14651	Pass	14652	Pass
14653	Pass	14654	Pass	14655	Pass	14656	Pass
14657	Pass	14658	Pass	14659	Pass	14660	Pass
14661	Pass	14662	Pass	14663	Pass	14664	Pass
14665	Pass	14666	Pass	14667	Pass	14668	Pass
14669	Pass	14670	Pass	14671	Pass	14672	Pass
14673	Pass	14674	Pass	14675	Pass	14676	Pass
14677	Pass	14678	Pass	14679	Pass	14680	Pass
14681	Pass	14682	Pass	14683	Pass	14684	Pass
14685	Pass	14686	Pass	14687	Pass	14688	Pass
14689	Pass	14690	Pass	14691	Pass	14692	Pass
14693	Pass	14694	Pass	14695	Pass	14696	Pass
14697	Pass	14698	Pass	14699	Pass	14700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory