

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/251/25	Model No.: KFARQ-6-90%	Date: 19-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 251/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25001 To 25100 And 25005A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25005A and removed from the Lot/Batch							
25001	Pass	25002	Pass	25003	Pass	25004	Pass
25005	Pass	25006	Pass	25007	Pass	25008	Pass
25009	Pass	25010	Pass	25011	Pass	25012	Pass
25013	Pass	25014	Pass	25015	Pass	25016	Pass
25017	Pass	25018	Pass	25019	Pass	25020	Pass
25021	Pass	25022	Pass	25023	Pass	25024	Pass
25025	Pass	25026	Pass	25027	Pass	25028	Pass
25029	Pass	25030	Pass	25031	Pass	25032	Pass
25033	Pass	25034	Pass	25035	Pass	25036	Pass
25037	Pass	25038	Pass	25039	Pass	25040	Pass
25041	Pass	25042	Pass	25043	Pass	25044	Pass
25045	Pass	25046	Pass	25047	Pass	25048	Pass
25049	Pass	25050	Pass	25051	Pass	25052	Pass
25053	Pass	25054	Pass	25055	Pass	25056	Pass
25057	Pass	25058	Pass	25059	Pass	25060	Pass
25061	Pass	25062	Pass	25063	Pass	25064	Pass
25065	Pass	25066	Pass	25067	Pass	25068	Pass
25069	Pass	25070	Pass	25071	Pass	25072	Pass
25073	Pass	25074	Pass	25075	Pass	25076	Pass
25077	Pass	25078	Pass	25079	Pass	25080	Pass
25081	Pass	25082	Pass	25083	Pass	25084	Pass
25085	Pass	25086	Pass	25087	Pass	25088	Pass
25089	Pass	25090	Pass	25091	Pass	25092	Pass
25093	Pass	25094	Pass	25095	Pass	25096	Pass
25097	Pass	25098	Pass	25099	Pass	25100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory