

HYDRO PRESSURE TEST

TC No.: HPT/A9/S/RQ/006/25	Model No.: KFSRQ-9-S	Date: 06-06-2025
Type and Capacity of Extinguisher	: KFSRQ-9-S-Kanex BC Dry Powder(SBC) SP Fire Extinguisher Cap. 9 Kg.	
Batch Number	: KFSRQ9S 006/25	
Batch Quantity	: 51.00 Nos.	
Serial Numbers	: 00251 To 300 And 255A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 255A and removed from the Lot/Batch							
251	Pass	252	Pass	253	Pass	254	Pass
255	Pass	256	Pass	257	Pass	258	Pass
259	Pass	260	Pass	261	Pass	262	Pass
263	Pass	264	Pass	265	Pass	266	Pass
267	Pass	268	Pass	269	Pass	270	Pass
271	Pass	272	Pass	273	Pass	274	Pass
275	Pass	276	Pass	277	Pass	278	Pass
279	Pass	280	Pass	281	Pass	282	Pass
283	Pass	284	Pass	285	Pass	286	Pass
287	Pass	288	Pass	289	Pass	290	Pass
291	Pass	292	Pass	293	Pass	294	Pass
295	Pass	296	Pass	297	Pass	298	Pass
299	Pass	300	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory