

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/158/25	Model No.: KFARQ-6-90%	Date: 26-06-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 158/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15701 To 15800 And 15705A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15705A and removed from the Lot/Batch							
15701	Pass	15702	Pass	15703	Pass	15704	Pass
15705	Pass	15706	Pass	15707	Pass	15708	Pass
15709	Pass	15710	Pass	15711	Pass	15712	Pass
15713	Pass	15714	Pass	15715	Pass	15716	Pass
15717	Pass	15718	Pass	15719	Pass	15720	Pass
15721	Pass	15722	Pass	15723	Pass	15724	Pass
15725	Pass	15726	Pass	15727	Pass	15728	Pass
15729	Pass	15730	Pass	15731	Pass	15732	Pass
15733	Pass	15734	Pass	15735	Pass	15736	Pass
15737	Pass	15738	Pass	15739	Pass	15740	Pass
15741	Pass	15742	Pass	15743	Pass	15744	Pass
15745	Pass	15746	Pass	15747	Pass	15748	Pass
15749	Pass	15750	Pass	15751	Pass	15752	Pass
15753	Pass	15754	Pass	15755	Pass	15756	Pass
15757	Pass	15758	Pass	15759	Pass	15760	Pass
15761	Pass	15762	Pass	15763	Pass	15764	Pass
15765	Pass	15766	Pass	15767	Pass	15768	Pass
15769	Pass	15770	Pass	15771	Pass	15772	Pass
15773	Pass	15774	Pass	15775	Pass	15776	Pass
15777	Pass	15778	Pass	15779	Pass	15780	Pass
15781	Pass	15782	Pass	15783	Pass	15784	Pass
15785	Pass	15786	Pass	15787	Pass	15788	Pass
15789	Pass	15790	Pass	15791	Pass	15792	Pass
15793	Pass	15794	Pass	15795	Pass	15796	Pass
15797	Pass	15798	Pass	15799	Pass	15800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory