

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/160/25	Model No.: KFARQ-6-90%	Date: 03-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 160/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15901 To 16000 And 15905A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15905A and removed from the Lot/Batch							
15901	Pass	15902	Pass	15903	Pass	15904	Pass
15905	Pass	15906	Pass	15907	Pass	15908	Pass
15909	Pass	15910	Pass	15911	Pass	15912	Pass
15913	Pass	15914	Pass	15915	Pass	15916	Pass
15917	Pass	15918	Pass	15919	Pass	15920	Pass
15921	Pass	15922	Pass	15923	Pass	15924	Pass
15925	Pass	15926	Pass	15927	Pass	15928	Pass
15929	Pass	15930	Pass	15931	Pass	15932	Pass
15933	Pass	15934	Pass	15935	Pass	15936	Pass
15937	Pass	15938	Pass	15939	Pass	15940	Pass
15941	Pass	15942	Pass	15943	Pass	15944	Pass
15945	Pass	15946	Pass	15947	Pass	15948	Pass
15949	Pass	15950	Pass	15951	Pass	15952	Pass
15953	Pass	15954	Pass	15955	Pass	15956	Pass
15957	Pass	15958	Pass	15959	Pass	15960	Pass
15961	Pass	15962	Pass	15963	Pass	15964	Pass
15965	Pass	15966	Pass	15967	Pass	15968	Pass
15969	Pass	15970	Pass	15971	Pass	15972	Pass
15973	Pass	15974	Pass	15975	Pass	15976	Pass
15977	Pass	15978	Pass	15979	Pass	15980	Pass
15981	Pass	15982	Pass	15983	Pass	15984	Pass
15985	Pass	15986	Pass	15987	Pass	15988	Pass
15989	Pass	15990	Pass	15991	Pass	15992	Pass
15993	Pass	15994	Pass	15995	Pass	15996	Pass
15997	Pass	15998	Pass	15999	Pass	16000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory