

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/170/25	Model No.: KFARQ-4-90%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 170/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16901 To 17000 And 16905A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16905A and removed from the Lot/Batch							
16901	Pass	16902	Pass	16903	Pass	16904	Pass
16905	Pass	16906	Pass	16907	Pass	16908	Pass
16909	Pass	16910	Pass	16911	Pass	16912	Pass
16913	Pass	16914	Pass	16915	Pass	16916	Pass
16917	Pass	16918	Pass	16919	Pass	16920	Pass
16921	Pass	16922	Pass	16923	Pass	16924	Pass
16925	Pass	16926	Pass	16927	Pass	16928	Pass
16929	Pass	16930	Pass	16931	Pass	16932	Pass
16933	Pass	16934	Pass	16935	Pass	16936	Pass
16937	Pass	16938	Pass	16939	Pass	16940	Pass
16941	Pass	16942	Pass	16943	Pass	16944	Pass
16945	Pass	16946	Pass	16947	Pass	16948	Pass
16949	Pass	16950	Pass	16951	Pass	16952	Pass
16953	Pass	16954	Pass	16955	Pass	16956	Pass
16957	Pass	16958	Pass	16959	Pass	16960	Pass
16961	Pass	16962	Pass	16963	Pass	16964	Pass
16965	Pass	16966	Pass	16967	Pass	16968	Pass
16969	Pass	16970	Pass	16971	Pass	16972	Pass
16973	Pass	16974	Pass	16975	Pass	16976	Pass
16977	Pass	16978	Pass	16979	Pass	16980	Pass
16981	Pass	16982	Pass	16983	Pass	16984	Pass
16985	Pass	16986	Pass	16987	Pass	16988	Pass
16989	Pass	16990	Pass	16991	Pass	16992	Pass
16993	Pass	16994	Pass	16995	Pass	16996	Pass
16997	Pass	16998	Pass	16999	Pass	17000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory