



Warranty Certificate

Date: 10-10-2025

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: R Square Marketing ServicesWarranty Start Date: 10-10-2025Warranty End Date: 09-10-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KCARQ-2-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 2 Kg.	1	As Per Annexure – I
2	KCARQ-4-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 4 Kg.	1	As Per Annexure – I
3	KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	33	As Per Annexure – I
4	KFARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	1	As Per Annexure – I
5	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	40	As Per Annexure – I
6	KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	1	As Per Annexure – I
7	KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	22	As Per Annexure – I
8	KFWSRQ-9-Kanex Water SP Fire Extinguisher Cap. 9 Ltr.	32	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/004567 Dated: 10-10-2025 P.O.No. 25-26/Gujrat/35A** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory