

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/207/25	Model No.: MARQ-6-50%	Date: 26-06-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 207/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20601 To 20700 And 20605A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20605A and removed from the Lot/Batch							
20601	Pass	20602	Pass	20603	Pass	20604	Pass
20605	Pass	20606	Pass	20607	Pass	20608	Pass
20609	Pass	20610	Pass	20611	Pass	20612	Pass
20613	Pass	20614	Pass	20615	Pass	20616	Pass
20617	Pass	20618	Pass	20619	Pass	20620	Pass
20621	Pass	20622	Pass	20623	Pass	20624	Pass
20625	Pass	20626	Pass	20627	Pass	20628	Pass
20629	Pass	20630	Pass	20631	Pass	20632	Pass
20633	Pass	20634	Pass	20635	Pass	20636	Pass
20637	Pass	20638	Pass	20639	Pass	20640	Pass
20641	Pass	20642	Pass	20643	Pass	20644	Pass
20645	Pass	20646	Pass	20647	Pass	20648	Pass
20649	Pass	20650	Pass	20651	Pass	20652	Pass
20653	Pass	20654	Pass	20655	Pass	20656	Pass
20657	Pass	20658	Pass	20659	Pass	20660	Pass
20661	Pass	20662	Pass	20663	Pass	20664	Pass
20665	Pass	20666	Pass	20667	Pass	20668	Pass
20669	Pass	20670	Pass	20671	Pass	20672	Pass
20673	Pass	20674	Pass	20675	Pass	20676	Pass
20677	Pass	20678	Pass	20679	Pass	20680	Pass
20681	Pass	20682	Pass	20683	Pass	20684	Pass
20685	Pass	20686	Pass	20687	Pass	20688	Pass
20689	Pass	20690	Pass	20691	Pass	20692	Pass
20693	Pass	20694	Pass	20695	Pass	20696	Pass
20697	Pass	20698	Pass	20699	Pass	20700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory