



# Warranty Certificate

Date: 11-10-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Sun Fire & Safety**Warranty Start Date:** 11-10-2025**Warranty End Date:** 10-10-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

**NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.**

| Sr.No. | Type & Capacity of Extinguishers                                      | Quantity | Sr. Nos.            |
|--------|-----------------------------------------------------------------------|----------|---------------------|
| 1      | KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg. | 2        | As Per Annexure – I |

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/004586 Dated: 11-10-2025 P.O.No. SFS/PO/25-26/015** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**