

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/177/25	Model No.: MARQ-6-40%	Date: 15-09-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 177/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17601 To 17700 And 17605A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
----------	--------	----------	--------	----------	--------	----------	--------

Burst test conducted on 17605A and removed from the Lot/Batch

17601	Pass	17602	Pass	17603	Pass	17604	Pass
17605	Pass	17606	Pass	17607	Pass	17608	Pass
17609	Pass	17610	Pass	17611	Pass	17612	Pass
17613	Pass	17614	Pass	17615	Pass	17616	Pass
17617	Pass	17618	Pass	17619	Pass	17620	Pass
17621	Pass	17622	Pass	17623	Pass	17624	Pass
17625	Pass	17626	Pass	17627	Pass	17628	Pass
17629	Pass	17630	Pass	17631	Pass	17632	Pass
17633	Pass	17634	Pass	17635	Pass	17636	Pass
17637	Pass	17638	Pass	17639	Pass	17640	Pass
17641	Pass	17642	Pass	17643	Pass	17644	Pass
17645	Pass	17646	Pass	17647	Pass	17648	Pass
17649	Pass	17650	Pass	17651	Pass	17652	Pass
17653	Pass	17654	Pass	17655	Pass	17656	Pass
17657	Pass	17658	Pass	17659	Pass	17660	Pass
17661	Pass	17662	Pass	17663	Pass	17664	Pass
17665	Pass	17666	Pass	17667	Pass	17668	Pass
17669	Pass	17670	Pass	17671	Pass	17672	Pass
17673	Pass	17674	Pass	17675	Pass	17676	Pass
17677	Pass	17678	Pass	17679	Pass	17680	Pass
17681	Pass	17682	Pass	17683	Pass	17684	Pass
17685	Pass	17686	Pass	17687	Pass	17688	Pass
17689	Pass	17690	Pass	17691	Pass	17692	Pass
17693	Pass	17694	Pass	17695	Pass	17696	Pass
17697	Pass	17698	Pass	17699	Pass	17700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory