

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/178/25	Model No.: MARQ-6-40%	Date: 15-09-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 178/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17701 To 17800 And 17705A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17705A and removed from the Lot/Batch							
17701	Pass	17702	Pass	17703	Pass	17704	Pass
17705	Pass	17706	Pass	17707	Pass	17708	Pass
17709	Pass	17710	Pass	17711	Pass	17712	Pass
17713	Pass	17714	Pass	17715	Pass	17716	Pass
17717	Pass	17718	Pass	17719	Pass	17720	Pass
17721	Pass	17722	Pass	17723	Pass	17724	Pass
17725	Pass	17726	Pass	17727	Pass	17728	Pass
17729	Pass	17730	Pass	17731	Pass	17732	Pass
17733	Pass	17734	Pass	17735	Pass	17736	Pass
17737	Pass	17738	Pass	17739	Pass	17740	Pass
17741	Pass	17742	Pass	17743	Pass	17744	Pass
17745	Pass	17746	Pass	17747	Pass	17748	Pass
17749	Pass	17750	Pass	17751	Pass	17752	Pass
17753	Pass	17754	Pass	17755	Pass	17756	Pass
17757	Pass	17758	Pass	17759	Pass	17760	Pass
17761	Pass	17762	Pass	17763	Pass	17764	Pass
17765	Pass	17766	Pass	17767	Pass	17768	Pass
17769	Pass	17770	Pass	17771	Pass	17772	Pass
17773	Pass	17774	Pass	17775	Pass	17776	Pass
17777	Pass	17778	Pass	17779	Pass	17780	Pass
17781	Pass	17782	Pass	17783	Pass	17784	Pass
17785	Pass	17786	Pass	17787	Pass	17788	Pass
17789	Pass	17790	Pass	17791	Pass	17792	Pass
17793	Pass	17794	Pass	17795	Pass	17796	Pass
17797	Pass	17798	Pass	17799	Pass	17800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory