

HELIUM LEAK DETECTION TEST

TC No.: HLD/A4/K/HQ/017/25

Model No.: KFKHQ-4

Date: 13-09-2025

Type and Capacity of Extinguisher : KFKHQ-4-Kanex F Class Kitchen Fire Extinguisher Cap. 4 Ltr.

Batch Number : KFKHQ4 017/25

Batch Quantity : 10 Nos.

Serial Numbers : 00161 To 170

Month of Manufacturing : Sep/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
161	Pass	162	Pass	163	Pass	164	Pass
165	Pass	166	Pass	167	Pass	168	Pass
169	Pass	170	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**