

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/A9/M/RQ/007/25        | Model No.: KFDMSRQ-9                                           | Date: 08-07-2025 |
| Type and Capacity of Extinguisher | : KFDMSRQ-9-Kanex D Type Metal SP Fire Extinguisher Cap. 9 Kg. |                  |
| Batch Number                      | : KFDMSRQ9 007/25                                              |                  |
| Batch Quantity                    | : 21.00 Nos.                                                   |                  |
| Serial Numbers                    | : 00121 To 140 And 125A                                        |                  |
| Month of Manufacturing            | : Jul/25                                                       |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 125A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 121                                                         | Pass   | 122      | Pass   | 123      | Pass   | 124      | Pass   |
| 125                                                         | Pass   | 126      | Pass   | 127      | Pass   | 128      | Pass   |
| 129                                                         | Pass   | 130      | Pass   | 131      | Pass   | 132      | Pass   |
| 133                                                         | Pass   | 134      | Pass   | 135      | Pass   | 136      | Pass   |
| 137                                                         | Pass   | 138      | Pass   | 139      | Pass   | 140      | Pass   |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**