

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/284/25	Model No.: KFARQ-6-50%	Date: 02-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 284/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28301 To 28400 And 28305A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28305A and removed from the Lot/Batch							
28301	Pass	28302	Pass	28303	Pass	28304	Pass
28305	Pass	28306	Pass	28307	Pass	28308	Pass
28309	Pass	28310	Pass	28311	Pass	28312	Pass
28313	Pass	28314	Pass	28315	Pass	28316	Pass
28317	Pass	28318	Pass	28319	Pass	28320	Pass
28321	Pass	28322	Pass	28323	Pass	28324	Pass
28325	Pass	28326	Pass	28327	Pass	28328	Pass
28329	Pass	28330	Pass	28331	Pass	28332	Pass
28333	Pass	28334	Pass	28335	Pass	28336	Pass
28337	Pass	28338	Pass	28339	Pass	28340	Pass
28341	Pass	28342	Pass	28343	Pass	28344	Pass
28345	Pass	28346	Pass	28347	Pass	28348	Pass
28349	Pass	28350	Pass	28351	Pass	28352	Pass
28353	Pass	28354	Pass	28355	Pass	28356	Pass
28357	Pass	28358	Pass	28359	Pass	28360	Pass
28361	Pass	28362	Pass	28363	Pass	28364	Pass
28365	Pass	28366	Pass	28367	Pass	28368	Pass
28369	Pass	28370	Pass	28371	Pass	28372	Pass
28373	Pass	28374	Pass	28375	Pass	28376	Pass
28377	Pass	28378	Pass	28379	Pass	28380	Pass
28381	Pass	28382	Pass	28383	Pass	28384	Pass
28385	Pass	28386	Pass	28387	Pass	28388	Pass
28389	Pass	28390	Pass	28391	Pass	28392	Pass
28393	Pass	28394	Pass	28395	Pass	28396	Pass
28397	Pass	28398	Pass	28399	Pass	28400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory