

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/310/25	Model No.: KFARQ-6-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 310/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 30901 To 31000 And 30905A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 30905A and removed from the Lot/Batch							
30901	Pass	30902	Pass	30903	Pass	30904	Pass
30905	Pass	30906	Pass	30907	Pass	30908	Pass
30909	Pass	30910	Pass	30911	Pass	30912	Pass
30913	Pass	30914	Pass	30915	Pass	30916	Pass
30917	Pass	30918	Pass	30919	Pass	30920	Pass
30921	Pass	30922	Pass	30923	Pass	30924	Pass
30925	Pass	30926	Pass	30927	Pass	30928	Pass
30929	Pass	30930	Pass	30931	Pass	30932	Pass
30933	Pass	30934	Pass	30935	Pass	30936	Pass
30937	Pass	30938	Pass	30939	Pass	30940	Pass
30941	Pass	30942	Pass	30943	Pass	30944	Pass
30945	Pass	30946	Pass	30947	Pass	30948	Pass
30949	Pass	30950	Pass	30951	Pass	30952	Pass
30953	Pass	30954	Pass	30955	Pass	30956	Pass
30957	Pass	30958	Pass	30959	Pass	30960	Pass
30961	Pass	30962	Pass	30963	Pass	30964	Pass
30965	Pass	30966	Pass	30967	Pass	30968	Pass
30969	Pass	30970	Pass	30971	Pass	30972	Pass
30973	Pass	30974	Pass	30975	Pass	30976	Pass
30977	Pass	30978	Pass	30979	Pass	30980	Pass
30981	Pass	30982	Pass	30983	Pass	30984	Pass
30985	Pass	30986	Pass	30987	Pass	30988	Pass
30989	Pass	30990	Pass	30991	Pass	30992	Pass
30993	Pass	30994	Pass	30995	Pass	30996	Pass
30997	Pass	30998	Pass	30999	Pass	31000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory