

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/298/25	Model No.: KFARQ-6-50%	Date: 16-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 298/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29701 To 29800 And 29705A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29705A and removed from the Lot/Batch							
29701	Pass	29702	Pass	29703	Pass	29704	Pass
29705	Pass	29706	Pass	29707	Pass	29708	Pass
29709	Pass	29710	Pass	29711	Pass	29712	Pass
29713	Pass	29714	Pass	29715	Pass	29716	Pass
29717	Pass	29718	Pass	29719	Pass	29720	Pass
29721	Pass	29722	Pass	29723	Pass	29724	Pass
29725	Pass	29726	Pass	29727	Pass	29728	Pass
29729	Pass	29730	Pass	29731	Pass	29732	Pass
29733	Pass	29734	Pass	29735	Pass	29736	Pass
29737	Pass	29738	Pass	29739	Pass	29740	Pass
29741	Pass	29742	Pass	29743	Pass	29744	Pass
29745	Pass	29746	Pass	29747	Pass	29748	Pass
29749	Pass	29750	Pass	29751	Pass	29752	Pass
29753	Pass	29754	Pass	29755	Pass	29756	Pass
29757	Pass	29758	Pass	29759	Pass	29760	Pass
29761	Pass	29762	Pass	29763	Pass	29764	Pass
29765	Pass	29766	Pass	29767	Pass	29768	Pass
29769	Pass	29770	Pass	29771	Pass	29772	Pass
29773	Pass	29774	Pass	29775	Pass	29776	Pass
29777	Pass	29778	Pass	29779	Pass	29780	Pass
29781	Pass	29782	Pass	29783	Pass	29784	Pass
29785	Pass	29786	Pass	29787	Pass	29788	Pass
29789	Pass	29790	Pass	29791	Pass	29792	Pass
29793	Pass	29794	Pass	29795	Pass	29796	Pass
29797	Pass	29798	Pass	29799	Pass	29800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory