

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/159/25	Model No.: KFARQ-6-90%	Date: 03-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 159/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 15801 To 15900 And 15805A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15805A and removed from the Lot/Batch							
15801	Pass	15802	Pass	15803	Pass	15804	Pass
15805	Pass	15806	Pass	15807	Pass	15808	Pass
15809	Pass	15810	Pass	15811	Pass	15812	Pass
15813	Pass	15814	Pass	15815	Pass	15816	Pass
15817	Pass	15818	Pass	15819	Pass	15820	Pass
15821	Pass	15822	Pass	15823	Pass	15824	Pass
15825	Pass	15826	Pass	15827	Pass	15828	Pass
15829	Pass	15830	Pass	15831	Pass	15832	Pass
15833	Pass	15834	Pass	15835	Pass	15836	Pass
15837	Pass	15838	Pass	15839	Pass	15840	Pass
15841	Pass	15842	Pass	15843	Pass	15844	Pass
15845	Pass	15846	Pass	15847	Pass	15848	Pass
15849	Pass	15850	Pass	15851	Pass	15852	Pass
15853	Pass	15854	Pass	15855	Pass	15856	Pass
15857	Pass	15858	Pass	15859	Pass	15860	Pass
15861	Pass	15862	Pass	15863	Pass	15864	Pass
15865	Pass	15866	Pass	15867	Pass	15868	Pass
15869	Pass	15870	Pass	15871	Pass	15872	Pass
15873	Pass	15874	Pass	15875	Pass	15876	Pass
15877	Pass	15878	Pass	15879	Pass	15880	Pass
15881	Pass	15882	Pass	15883	Pass	15884	Pass
15885	Pass	15886	Pass	15887	Pass	15888	Pass
15889	Pass	15890	Pass	15891	Pass	15892	Pass
15893	Pass	15894	Pass	15895	Pass	15896	Pass
15897	Pass	15898	Pass	15899	Pass	15900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory