

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/224/25     | Model No.: MARQ-6-50%                                          | Date: 18-07-2025 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 224/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 22301 To 22400 And 22305A                                    |                  |
| Month of Manufacturing            | : Jul/25                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 22305A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 22301                                                         | Pass   | 22302    | Pass   | 22303    | Pass   | 22304    | Pass   |
| 22305                                                         | Pass   | 22306    | Pass   | 22307    | Pass   | 22308    | Pass   |
| 22309                                                         | Pass   | 22310    | Pass   | 22311    | Pass   | 22312    | Pass   |
| 22313                                                         | Pass   | 22314    | Pass   | 22315    | Pass   | 22316    | Pass   |
| 22317                                                         | Pass   | 22318    | Pass   | 22319    | Pass   | 22320    | Pass   |
| 22321                                                         | Pass   | 22322    | Pass   | 22323    | Pass   | 22324    | Pass   |
| 22325                                                         | Pass   | 22326    | Pass   | 22327    | Pass   | 22328    | Pass   |
| 22329                                                         | Pass   | 22330    | Pass   | 22331    | Pass   | 22332    | Pass   |
| 22333                                                         | Pass   | 22334    | Pass   | 22335    | Pass   | 22336    | Pass   |
| 22337                                                         | Pass   | 22338    | Pass   | 22339    | Pass   | 22340    | Pass   |
| 22341                                                         | Pass   | 22342    | Pass   | 22343    | Pass   | 22344    | Pass   |
| 22345                                                         | Pass   | 22346    | Pass   | 22347    | Pass   | 22348    | Pass   |
| 22349                                                         | Pass   | 22350    | Pass   | 22351    | Pass   | 22352    | Pass   |
| 22353                                                         | Pass   | 22354    | Pass   | 22355    | Pass   | 22356    | Pass   |
| 22357                                                         | Pass   | 22358    | Pass   | 22359    | Pass   | 22360    | Pass   |
| 22361                                                         | Pass   | 22362    | Pass   | 22363    | Pass   | 22364    | Pass   |
| 22365                                                         | Pass   | 22366    | Pass   | 22367    | Pass   | 22368    | Pass   |
| 22369                                                         | Pass   | 22370    | Pass   | 22371    | Pass   | 22372    | Pass   |
| 22373                                                         | Pass   | 22374    | Pass   | 22375    | Pass   | 22376    | Pass   |
| 22377                                                         | Pass   | 22378    | Pass   | 22379    | Pass   | 22380    | Pass   |
| 22381                                                         | Pass   | 22382    | Pass   | 22383    | Pass   | 22384    | Pass   |
| 22385                                                         | Pass   | 22386    | Pass   | 22387    | Pass   | 22388    | Pass   |
| 22389                                                         | Pass   | 22390    | Pass   | 22391    | Pass   | 22392    | Pass   |
| 22393                                                         | Pass   | 22394    | Pass   | 22395    | Pass   | 22396    | Pass   |
| 22397                                                         | Pass   | 22398    | Pass   | 22399    | Pass   | 22400    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**