

HELIUM LEAK DETECTION TEST

TC No.: HLD/MOD5/CA/HQ/014/25	Model No.: KMCHQ-5-FE36	Date: 10-09-2025
Type and Capacity of Extinguisher	: KMCHQ-5-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCHQ5 014/25	
Batch Quantity	: 50 Nos.	
Serial Numbers	: 00651 To 700	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
651	Pass	652	Pass	653	Pass	654	Pass
655	Pass	656	Pass	657	Pass	658	Pass
659	Pass	660	Pass	661	Pass	662	Pass
663	Pass	664	Pass	665	Pass	666	Pass
667	Pass	668	Pass	669	Pass	670	Pass
671	Pass	672	Pass	673	Pass	674	Pass
675	Pass	676	Pass	677	Pass	678	Pass
679	Pass	680	Pass	681	Pass	682	Pass
683	Pass	684	Pass	685	Pass	686	Pass
687	Pass	688	Pass	689	Pass	690	Pass
691	Pass	692	Pass	693	Pass	694	Pass
695	Pass	696	Pass	697	Pass	698	Pass
699	Pass	700	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory