

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/236/25	Model No.: KFARQ-6-50%	Date: 18-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 236/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23501 To 23600 And 23505A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23505A and removed from the Lot/Batch							
23501	Pass	23502	Pass	23503	Pass	23504	Pass
23505	Pass	23506	Pass	23507	Pass	23508	Pass
23509	Pass	23510	Pass	23511	Pass	23512	Pass
23513	Pass	23514	Pass	23515	Pass	23516	Pass
23517	Pass	23518	Pass	23519	Pass	23520	Pass
23521	Pass	23522	Pass	23523	Pass	23524	Pass
23525	Pass	23526	Pass	23527	Pass	23528	Pass
23529	Pass	23530	Pass	23531	Pass	23532	Pass
23533	Pass	23534	Pass	23535	Pass	23536	Pass
23537	Pass	23538	Pass	23539	Pass	23540	Pass
23541	Pass	23542	Pass	23543	Pass	23544	Pass
23545	Pass	23546	Pass	23547	Pass	23548	Pass
23549	Pass	23550	Pass	23551	Pass	23552	Pass
23553	Pass	23554	Pass	23555	Pass	23556	Pass
23557	Pass	23558	Pass	23559	Pass	23560	Pass
23561	Pass	23562	Pass	23563	Pass	23564	Pass
23565	Pass	23566	Pass	23567	Pass	23568	Pass
23569	Pass	23570	Pass	23571	Pass	23572	Pass
23573	Pass	23574	Pass	23575	Pass	23576	Pass
23577	Pass	23578	Pass	23579	Pass	23580	Pass
23581	Pass	23582	Pass	23583	Pass	23584	Pass
23585	Pass	23586	Pass	23587	Pass	23588	Pass
23589	Pass	23590	Pass	23591	Pass	23592	Pass
23593	Pass	23594	Pass	23595	Pass	23596	Pass
23597	Pass	23598	Pass	23599	Pass	23600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory