

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/229/25	Model No.: KFARQ-6-50%	Date: 11-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 229/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22801 To 22900 And 22805A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22805A and removed from the Lot/Batch							
22801	Pass	22802	Pass	22803	Pass	22804	Pass
22805	Pass	22806	Pass	22807	Pass	22808	Pass
22809	Pass	22810	Pass	22811	Pass	22812	Pass
22813	Pass	22814	Pass	22815	Pass	22816	Pass
22817	Pass	22818	Pass	22819	Pass	22820	Pass
22821	Pass	22822	Pass	22823	Pass	22824	Pass
22825	Pass	22826	Pass	22827	Pass	22828	Pass
22829	Pass	22830	Pass	22831	Pass	22832	Pass
22833	Pass	22834	Pass	22835	Pass	22836	Pass
22837	Pass	22838	Pass	22839	Pass	22840	Pass
22841	Pass	22842	Pass	22843	Pass	22844	Pass
22845	Pass	22846	Pass	22847	Pass	22848	Pass
22849	Pass	22850	Pass	22851	Pass	22852	Pass
22853	Pass	22854	Pass	22855	Pass	22856	Pass
22857	Pass	22858	Pass	22859	Pass	22860	Pass
22861	Pass	22862	Pass	22863	Pass	22864	Pass
22865	Pass	22866	Pass	22867	Pass	22868	Pass
22869	Pass	22870	Pass	22871	Pass	22872	Pass
22873	Pass	22874	Pass	22875	Pass	22876	Pass
22877	Pass	22878	Pass	22879	Pass	22880	Pass
22881	Pass	22882	Pass	22883	Pass	22884	Pass
22885	Pass	22886	Pass	22887	Pass	22888	Pass
22889	Pass	22890	Pass	22891	Pass	22892	Pass
22893	Pass	22894	Pass	22895	Pass	22896	Pass
22897	Pass	22898	Pass	22899	Pass	22900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory