

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/309/25	Model No.: MARQ-6-50%	Date: 10-10-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 309/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 30801 To 30900 And 30805A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 30805A and removed from the Lot/Batch							
30801	Pass	30802	Pass	30803	Pass	30804	Pass
30805	Pass	30806	Pass	30807	Pass	30808	Pass
30809	Pass	30810	Pass	30811	Pass	30812	Pass
30813	Pass	30814	Pass	30815	Pass	30816	Pass
30817	Pass	30818	Pass	30819	Pass	30820	Pass
30821	Pass	30822	Pass	30823	Pass	30824	Pass
30825	Pass	30826	Pass	30827	Pass	30828	Pass
30829	Pass	30830	Pass	30831	Pass	30832	Pass
30833	Pass	30834	Pass	30835	Pass	30836	Pass
30837	Pass	30838	Pass	30839	Pass	30840	Pass
30841	Pass	30842	Pass	30843	Pass	30844	Pass
30845	Pass	30846	Pass	30847	Pass	30848	Pass
30849	Pass	30850	Pass	30851	Pass	30852	Pass
30853	Pass	30854	Pass	30855	Pass	30856	Pass
30857	Pass	30858	Pass	30859	Pass	30860	Pass
30861	Pass	30862	Pass	30863	Pass	30864	Pass
30865	Pass	30866	Pass	30867	Pass	30868	Pass
30869	Pass	30870	Pass	30871	Pass	30872	Pass
30873	Pass	30874	Pass	30875	Pass	30876	Pass
30877	Pass	30878	Pass	30879	Pass	30880	Pass
30881	Pass	30882	Pass	30883	Pass	30884	Pass
30885	Pass	30886	Pass	30887	Pass	30888	Pass
30889	Pass	30890	Pass	30891	Pass	30892	Pass
30893	Pass	30894	Pass	30895	Pass	30896	Pass
30897	Pass	30898	Pass	30899	Pass	30900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory