

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/A50/RQ/042/25	Model No.: KMPRQ-5-50%	Date: 14-08-2025
Type and Capacity of Extinguisher	: KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMPRQ50%5 042/25	
Batch Quantity	: 100.00 Nos.	
Serial Numbers	: 04101 To 4200	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 04101 To 4200 and removed from the Lot/Batch							
4101	Pass	4102	Pass	4103	Pass	4104	Pass
4105	Pass	4106	Pass	4107	Pass	4108	Pass
4109	Pass	4110	Pass	4111	Pass	4112	Pass
4113	Pass	4114	Pass	4115	Pass	4116	Pass
4117	Pass	4118	Pass	4119	Pass	4120	Pass
4121	Pass	4122	Pass	4123	Pass	4124	Pass
4125	Pass	4126	Pass	4127	Pass	4128	Pass
4129	Pass	4130	Pass	4131	Pass	4132	Pass
4133	Pass	4134	Pass	4135	Pass	4136	Pass
4137	Pass	4138	Pass	4139	Pass	4140	Pass
4141	Pass	4142	Pass	4143	Pass	4144	Pass
4145	Pass	4146	Pass	4147	Pass	4148	Pass
4149	Pass	4150	Pass	4151	Pass	4152	Pass
4153	Pass	4154	Pass	4155	Pass	4156	Pass
4157	Pass	4158	Pass	4159	Pass	4160	Pass
4161	Pass	4162	Pass	4163	Pass	4164	Pass
4165	Pass	4166	Pass	4167	Pass	4168	Pass
4169	Pass	4170	Pass	4171	Pass	4172	Pass
4173	Pass	4174	Pass	4175	Pass	4176	Pass
4177	Pass	4178	Pass	4179	Pass	4180	Pass
4181	Pass	4182	Pass	4183	Pass	4184	Pass
4185	Pass	4186	Pass	4187	Pass	4188	Pass
4189	Pass	4190	Pass	4191	Pass	4192	Pass
4193	Pass	4194	Pass	4195	Pass	4196	Pass
4197	Pass	4198	Pass	4199	Pass	4200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory