

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/195/25	Model No.: KFARQ-6-90%	Date: 15-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 195/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19401 To 19500 And 19405A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19405A and removed from the Lot/Batch							
19401	Pass	19402	Pass	19403	Pass	19404	Pass
19405	Pass	19406	Pass	19407	Pass	19408	Pass
19409	Pass	19410	Pass	19411	Pass	19412	Pass
19413	Pass	19414	Pass	19415	Pass	19416	Pass
19417	Pass	19418	Pass	19419	Pass	19420	Pass
19421	Pass	19422	Pass	19423	Pass	19424	Pass
19425	Pass	19426	Pass	19427	Pass	19428	Pass
19429	Pass	19430	Pass	19431	Pass	19432	Pass
19433	Pass	19434	Pass	19435	Pass	19436	Pass
19437	Pass	19438	Pass	19439	Pass	19440	Pass
19441	Pass	19442	Pass	19443	Pass	19444	Pass
19445	Pass	19446	Pass	19447	Pass	19448	Pass
19449	Pass	19450	Pass	19451	Pass	19452	Pass
19453	Pass	19454	Pass	19455	Pass	19456	Pass
19457	Pass	19458	Pass	19459	Pass	19460	Pass
19461	Pass	19462	Pass	19463	Pass	19464	Pass
19465	Pass	19466	Pass	19467	Pass	19468	Pass
19469	Pass	19470	Pass	19471	Pass	19472	Pass
19473	Pass	19474	Pass	19475	Pass	19476	Pass
19477	Pass	19478	Pass	19479	Pass	19480	Pass
19481	Pass	19482	Pass	19483	Pass	19484	Pass
19485	Pass	19486	Pass	19487	Pass	19488	Pass
19489	Pass	19490	Pass	19491	Pass	19492	Pass
19493	Pass	19494	Pass	19495	Pass	19496	Pass
19497	Pass	19498	Pass	19499	Pass	19500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory