

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/196/25	Model No.: KFARQ-6-90%	Date: 18-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 196/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19501 To 19600 And 19505A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19505A and removed from the Lot/Batch							
19501	Pass	19502	Pass	19503	Pass	19504	Pass
19505	Pass	19506	Pass	19507	Pass	19508	Pass
19509	Pass	19510	Pass	19511	Pass	19512	Pass
19513	Pass	19514	Pass	19515	Pass	19516	Pass
19517	Pass	19518	Pass	19519	Pass	19520	Pass
19521	Pass	19522	Pass	19523	Pass	19524	Pass
19525	Pass	19526	Pass	19527	Pass	19528	Pass
19529	Pass	19530	Pass	19531	Pass	19532	Pass
19533	Pass	19534	Pass	19535	Pass	19536	Pass
19537	Pass	19538	Pass	19539	Pass	19540	Pass
19541	Pass	19542	Pass	19543	Pass	19544	Pass
19545	Pass	19546	Pass	19547	Pass	19548	Pass
19549	Pass	19550	Pass	19551	Pass	19552	Pass
19553	Pass	19554	Pass	19555	Pass	19556	Pass
19557	Pass	19558	Pass	19559	Pass	19560	Pass
19561	Pass	19562	Pass	19563	Pass	19564	Pass
19565	Pass	19566	Pass	19567	Pass	19568	Pass
19569	Pass	19570	Pass	19571	Pass	19572	Pass
19573	Pass	19574	Pass	19575	Pass	19576	Pass
19577	Pass	19578	Pass	19579	Pass	19580	Pass
19581	Pass	19582	Pass	19583	Pass	19584	Pass
19585	Pass	19586	Pass	19587	Pass	19588	Pass
19589	Pass	19590	Pass	19591	Pass	19592	Pass
19593	Pass	19594	Pass	19595	Pass	19596	Pass
19597	Pass	19598	Pass	19599	Pass	19600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory