

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/227/25	Model No.: KFARQ-6-90%	Date: 19-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 227/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22601 To 22700 And 22605A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22605A and removed from the Lot/Batch							
22601	Pass	22602	Pass	22603	Pass	22604	Pass
22605	Pass	22606	Pass	22607	Pass	22608	Pass
22609	Pass	22610	Pass	22611	Pass	22612	Pass
22613	Pass	22614	Pass	22615	Pass	22616	Pass
22617	Pass	22618	Pass	22619	Pass	22620	Pass
22621	Pass	22622	Pass	22623	Pass	22624	Pass
22625	Pass	22626	Pass	22627	Pass	22628	Pass
22629	Pass	22630	Pass	22631	Pass	22632	Pass
22633	Pass	22634	Pass	22635	Pass	22636	Pass
22637	Pass	22638	Pass	22639	Pass	22640	Pass
22641	Pass	22642	Pass	22643	Pass	22644	Pass
22645	Pass	22646	Pass	22647	Pass	22648	Pass
22649	Pass	22650	Pass	22651	Pass	22652	Pass
22653	Pass	22654	Pass	22655	Pass	22656	Pass
22657	Pass	22658	Pass	22659	Pass	22660	Pass
22661	Pass	22662	Pass	22663	Pass	22664	Pass
22665	Pass	22666	Pass	22667	Pass	22668	Pass
22669	Pass	22670	Pass	22671	Pass	22672	Pass
22673	Pass	22674	Pass	22675	Pass	22676	Pass
22677	Pass	22678	Pass	22679	Pass	22680	Pass
22681	Pass	22682	Pass	22683	Pass	22684	Pass
22685	Pass	22686	Pass	22687	Pass	22688	Pass
22689	Pass	22690	Pass	22691	Pass	22692	Pass
22693	Pass	22694	Pass	22695	Pass	22696	Pass
22697	Pass	22698	Pass	22699	Pass	22700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory