

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/065/25	Model No.: KMCRQ-5	Date: 20-09-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 065/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03201 To 3250	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03201 To 3250 and removed from the Lot/Batch							
3201	Pass	3202	Pass	3203	Pass	3204	Pass
3205	Pass	3206	Pass	3207	Pass	3208	Pass
3209	Pass	3210	Pass	3211	Pass	3212	Pass
3213	Pass	3214	Pass	3215	Pass	3216	Pass
3217	Pass	3218	Pass	3219	Pass	3220	Pass
3221	Pass	3222	Pass	3223	Pass	3224	Pass
3225	Pass	3226	Pass	3227	Pass	3228	Pass
3229	Pass	3230	Pass	3231	Pass	3232	Pass
3233	Pass	3234	Pass	3235	Pass	3236	Pass
3237	Pass	3238	Pass	3239	Pass	3240	Pass
3241	Pass	3242	Pass	3243	Pass	3244	Pass
3245	Pass	3246	Pass	3247	Pass	3248	Pass
3249	Pass	3250	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory