

HYDRO PRESSURE TEST

TC No.: HPT/A4/K/HQ/016/25	Model No.: KFKHQ-4	Date: 27-08-2025
Type and Capacity of Extinguisher	: KFKHQ-4-Kanex F Class Kitchen Fire Extinguisher Cap. 4 Ltr.	
Batch Number	: KFKHQ4 016/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00151 To 160	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00151 To 160 and removed from the Lot/Batch							
151	Pass	152	Pass	153	Pass	154	Pass
155	Pass	156	Pass	157	Pass	158	Pass
159	Pass	160	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory