

HYDRO PRESSURE TEST

TC No.: HPT/MM9/SP/RQ/025/25	Model No.: MMSRQ-9	Date: 26-09-2025
Type and Capacity of Extinguisher	: MMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: MMSRQ9 025/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02401 To 2500 And 2405A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2405A and removed from the Lot/Batch							
2401	Pass	2402	Pass	2403	Pass	2404	Pass
2405	Pass	2406	Pass	2407	Pass	2408	Pass
2409	Pass	2410	Pass	2411	Pass	2412	Pass
2413	Pass	2414	Pass	2415	Pass	2416	Pass
2417	Pass	2418	Pass	2419	Pass	2420	Pass
2421	Pass	2422	Pass	2423	Pass	2424	Pass
2425	Pass	2426	Pass	2427	Pass	2428	Pass
2429	Pass	2430	Pass	2431	Pass	2432	Pass
2433	Pass	2434	Pass	2435	Pass	2436	Pass
2437	Pass	2438	Pass	2439	Pass	2440	Pass
2441	Pass	2442	Pass	2443	Pass	2444	Pass
2445	Pass	2446	Pass	2447	Pass	2448	Pass
2449	Pass	2450	Pass	2451	Pass	2452	Pass
2453	Pass	2454	Pass	2455	Pass	2456	Pass
2457	Pass	2458	Pass	2459	Pass	2460	Pass
2461	Pass	2462	Pass	2463	Pass	2464	Pass
2465	Pass	2466	Pass	2467	Pass	2468	Pass
2469	Pass	2470	Pass	2471	Pass	2472	Pass
2473	Pass	2474	Pass	2475	Pass	2476	Pass
2477	Pass	2478	Pass	2479	Pass	2480	Pass
2481	Pass	2482	Pass	2483	Pass	2484	Pass
2485	Pass	2486	Pass	2487	Pass	2488	Pass
2489	Pass	2490	Pass	2491	Pass	2492	Pass
2493	Pass	2494	Pass	2495	Pass	2496	Pass
2497	Pass	2498	Pass	2499	Pass	2500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory