

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/244/25	Model No.: MARQ-6-50%	Date: 26-07-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 244/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24301 To 24400 And 24305A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24305A and removed from the Lot/Batch							
24301	Pass	24302	Pass	24303	Pass	24304	Pass
24305	Pass	24306	Pass	24307	Pass	24308	Pass
24309	Pass	24310	Pass	24311	Pass	24312	Pass
24313	Pass	24314	Pass	24315	Pass	24316	Pass
24317	Pass	24318	Pass	24319	Pass	24320	Pass
24321	Pass	24322	Pass	24323	Pass	24324	Pass
24325	Pass	24326	Pass	24327	Pass	24328	Pass
24329	Pass	24330	Pass	24331	Pass	24332	Pass
24333	Pass	24334	Pass	24335	Pass	24336	Pass
24337	Pass	24338	Pass	24339	Pass	24340	Pass
24341	Pass	24342	Pass	24343	Pass	24344	Pass
24345	Pass	24346	Pass	24347	Pass	24348	Pass
24349	Pass	24350	Pass	24351	Pass	24352	Pass
24353	Pass	24354	Pass	24355	Pass	24356	Pass
24357	Pass	24358	Pass	24359	Pass	24360	Pass
24361	Pass	24362	Pass	24363	Pass	24364	Pass
24365	Pass	24366	Pass	24367	Pass	24368	Pass
24369	Pass	24370	Pass	24371	Pass	24372	Pass
24373	Pass	24374	Pass	24375	Pass	24376	Pass
24377	Pass	24378	Pass	24379	Pass	24380	Pass
24381	Pass	24382	Pass	24383	Pass	24384	Pass
24385	Pass	24386	Pass	24387	Pass	24388	Pass
24389	Pass	24390	Pass	24391	Pass	24392	Pass
24393	Pass	24394	Pass	24395	Pass	24396	Pass
24397	Pass	24398	Pass	24399	Pass	24400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory