

# HYDRO PRESSURE TEST

|                                   |                                                                           |                  |
|-----------------------------------|---------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD10/A90/RQ/014/25   | Model No.: KMPRQ-10-90%                                                   | Date: 24-07-2025 |
| Type and Capacity of Extinguisher | : KMPRQ-10-90%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 10 Kg. |                  |
| Batch Number                      | : KMPRQ90%10 014/25                                                       |                  |
| Batch Quantity                    | : 20.00 Nos.                                                              |                  |
| Serial Numbers                    | : 00261 To 280                                                            |                  |
| Month of Manufacturing            | : Jul/25                                                                  |                  |

| Sr. Nos.                                                            | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00261 To 280 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 261                                                                 | Pass   | 262      | Pass   | 263      | Pass   | 264      | Pass   |
| 265                                                                 | Pass   | 266      | Pass   | 267      | Pass   | 268      | Pass   |
| 269                                                                 | Pass   | 270      | Pass   | 271      | Pass   | 272      | Pass   |
| 273                                                                 | Pass   | 274      | Pass   | 275      | Pass   | 276      | Pass   |
| 277                                                                 | Pass   | 278      | Pass   | 279      | Pass   | 280      | Pass   |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**